



2010 Annual Drinking Water Quality Report

PWSID No. MD0120001

Dear City of Aberdeen Resident:

July 1, 2011

The Department of Public Works is pleased to provide to you the Annual Drinking Water Quality Report. This report shows the results of our monitoring for the period of January 1st to December 31st, 2010 (except as noted) and is designed to inform you about the quality of water and services the City delivers to you every day. We are committed to ensuring the quality of your water, and our singular goal is to provide you with a safe and dependable supply of drinking water.

The Public Works Department is pleased to report that our drinking water is safe and meets federal and state requirements. This report shows our water quality and what it means. The City of Aberdeen routinely monitors for contaminants in your drinking water according to Federal and State laws and under EPA guidelines.

Our water source is from sixteen ground water wells supplied through underground geological rock formations along the Atlantic Coastal Plain. Additionally, the City receives up to 500,000 gallons of water per day from City of Havre de Grace water treatment plant which supplies Harford County, who, in turn sells the water to Aberdeen. Their plant is supplied by water from the Susquehanna River. Altogether, we use an average of 1.7 million gallons per day to supply the City.

As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals and radioactive substances. All drinking water, ***including bottled drinking water***, may be reasonably expected to contain at least small amounts of some contaminants. ***It's important to remember that the presence of these contaminants does not necessarily pose a health risk.***

If you have any questions about this report or your water utility, please contact Paul Visser, Superintendent of Water/Wastewater Operations (410) 272-2650. We want our valued citizens to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled City Council meetings. They are held on the second and fourth Mondays of each month beginning at 7:00 p.m.

Paul M. Visser
Superintendent of Water

What does all this information mean?

As you will see in the following tables, our system had NO VIOLATIONS and very few detects. We're proud that your drinking water meets or exceeds all Federal, State and EPA requirements. We have learned through our monitoring and testing that some constituents have been present in the finished water and we will continue to monitor for **all** identified constituents. Again, it is important to remember that the EPA has determined that your water IS SAFE at these levels.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, *including bottled water*, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants *does not* necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at (800) 426-4791.

Definitions

In this report you may find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) or Nanograms per liter (nanograms/l) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Parts per quadrillion (ppq) or Picograms per liter (picograms/l) - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Millirems per year (mrem/yr) - measure of radiation absorbed by the body.

Million Fibers per Liter (MFL) - million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water.

Turbidity in excess of 5 NTU is just noticeable to the average person.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Detected Contaminants – City Water Supply

In addition to the many constituents that were subject to testing but not found, the City did find some regulated constituents present in the water system at levels *below the maximum allowable level (MCL)* which is determined safe by the EPA. These constituents are shown below, along with the MCL and MCL goal for each one detected. The State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, although accurate, is more than a year old as indicated by date (mm/yy).

Regulated Contaminant	Violation Y/N	Level Detected	Unit of Measure	Maximum Contaminant Level (MCL)	MCL Goal	Likely Source of Contamination
Total Coliform (% of positive tests)	N	0.0%		Presence of coliform bacteria in <5% of monthly samples	0	Naturally present in the environment. In 2010, 182 samples were tested, all samples were negative
*Lead For 2008	N	<0.002	ppm	AL = 0.015 (90 th percentile)	0	Corrosion of household plumbing systems; erosion of natural deposits
Copper For 2008	N	0.040	ppm	AL = 1.3 (90 th percentile)	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
**Fluoride	N	0.20 – 1.57 0.85 (Avg)	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
† Nitrates (as Nitrogen)	N	2.7	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Chlorine (as Cl ₂)	N	0.43 – 2.43 1.41 (Avg)	ppm	4	4	Water additive to control microbes
Tetrachloroethylene	N	1.2	ppb	5	0	Leaching from PVC pipes, discharge from factories and dry cleaners
Dibromo - chloromethane	N	0.51	ppb	see TTHM		Byproduct of drinking water chlorination
†† TTHM (Total trihalomethanes)	N	2.2 – 64.1 15.0 (Avg)	ppb	80	40	Byproduct of drinking water chlorination Rolling yearly average by quarter
HAA5 (Haloacetic Acids)	N	<1.0 – 53.0 11.9 (Avg)	ppb	60	30	Byproduct of drinking water chlorination Rolling yearly average by quarter

* Lead: “If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Aberdeen is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the EPA Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.”

** Fluoride: Some people who drink water containing fluoride in excess of the MCL over many years could get bone disease, including pain and tenderness of the bones. Fluoride in drinking water at half the MCL or more may cause mottling of children’s teeth, usually in children less than nine years old. Mottling, also known as dental fluorosis, may include brown staining and/or pitting of the teeth, and occurs only in developing teeth before they erupt from the gums.

† Nitrates: As a precaution we always notify physicians and health care providers in this area if there is ever a higher than normal level of nitrates in the water supply.

†† TTHM: Some people who drink water containing trihalomethanes in excess of the MCL over many years experience problems with their liver, kidneys, or central nervous systems, and may have increased risk of getting cancer.

Detected Contaminants – City Water Supply (cont.)

Unregulated Contaminant	Violation Y/N	Level Detected	Unit of Measure	Standard	Likely Source of Contamination
Sulfate For 2009	N	17	ppm	250 (Secondary Drinking Water Regulation)	Naturally occurring
Sodium For 2009	N	30	ppm	30 – 60 (Advisory Level)	Naturally occurring
Methyl-tert-butyl-ether (MTBE)	N	0.61 – 0.92 0.79 (Avg)	ppb	20 (Advisory Level)	Gasoline additive
Perchlorate	N	<0.98	ppb	1.0 (State Advisory Level)	Byproduct of explosives, fertilizer

Detected Contaminants – County Water Supply

Harford County is required to monitor and report their water quality under the same EPA and Maryland Department of the Environment regulations. In the water that we purchase from the County, they did find some constituents present in the water system at levels *below the maximum allowable level (MCL)* which is determined safe by the EPA. These constituents are shown below, along with the MCL and MCL goal for each one detected. The water supplied to the City by Harford County is drawn from the Susquehanna River and is processed in Havre de Grace. Additional information about the County water system and water quality can be access on the web at www.co.ha.md.us/dpw/ws/waterquality.html.

Regulated Contaminant	Violation Y/N	Level Detected	Unit of Measure	Maximum Contaminant Level (MCL)	MCL Goal	Likely Source of Contamination
Total Coliform (% of positive tests)	N	1.0%		Presence of coliform bacteria in <5% of monthly samples	0	Naturally present in the environment. In 2010, 1268 samples were tested with only 1 positive, and retest was negative
Barium	N	0.05	ppm	2	2	Discharge of drilling waste; discharge from metal refineries; erosion of natural deposits
Fluoride	N	1.5	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrates (as Nitrogen)	N	5.0	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Copper For 2008	N	0.10	ppm	AL = 1.3 (90 th percentile)	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead For 2008	N	0	ppb	AL = 15 (90 th percentile)	0	Corrosion of household plumbing systems; erosion of natural deposits
Chlorine (as Cl ₂)	N	3.5	ppm	4	4	Water additive to control microbes
Chromium	N	2.0	ppb	100	100	Erosion. Discharge from steel and pulp mills.
Toluene	N	0.2	ppb	1000	1000	Discharge from petroleum refineries.
Xylene, Total	N	0.3	ppb	10,000	10,000	Discharge from petroleum factories; Discharge from chemical factories.
TTHM, For 2009 & 2010 (Total trihalomethanes)	N	36	ppb	80	40	Byproduct of drinking water chlorination Rolling yearly average by quarter
HAA5 (Haloacetic Acids For 2009 & 2010)	N	49	ppb	60	30	Byproduct of drinking water chlorination Rolling yearly average by quarter

Detected Contaminants – County Water Supply (cont.)

Unregulated Contaminant	Violation Y/N	Level Detected	Unit of Measure	Standard	Likely Source of Contamination
Sodium	N	14.1 – 29.7 20.2 (Avg)	ppm	30 – 60 (Advisory Level)	Naturally occurring
Chloride	N	5 – 32 15 (Avg)	ppm	250 (Secondary Drinking Water Regulation)	Naturally occurring
Sulfate	N	21 – 57 36 (Avg)	ppm	250 (Secondary Drinking Water Regulation)	Naturally occurring
Phenolics (Total)	N	ND – 0.02 0.01 (Avg)	ppm	n/a (Secondary Drinking Water Regulation)	Discharge from factories, leaching from gas storage tanks & landfills

Health information

It is important to understand that the detection of these substances in the drinking water does not constitute a known threat to public health because they were found only at levels *less than* the MCL and *below* the level that EPA currently feels may constitute a health threat. The MCL's are set at very stringent levels, and the City's water has proved to be below those levels for the constituents listed above.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800) 426-4791.

City Wells - Perchlorate information and Update

In April, 2002 the City received information from Aberdeen Proving Ground that a compound called **perchlorate** was detected in the groundwater in the vicinity of the City's well field. Since that time, the City has been providing information on this subject to City residents through the media, our web page and City council meetings. The following information provides an update on this subject as of the date of this report.

Perchlorate is an unregulated contaminant that is an ingredient in a variety of products including air bag inflators, electronic tubes, lubricating oils, rocket propellant, explosives and other commercial and agricultural applications.

At the direction of the Maryland Department of the Environment, the City has been managing the wells to ensure that the level of perchlorate in the finished water does not exceed 1.0 ppb (the level established by MDE in the absence of an EPA standard). The City has currently installed perchlorate filtration units on several of its wells that was completed in fall of 2005.

The Department of Public Works will ensure that all measures will be taken to address this issue and that our drinking water meets or exceeds all EPA drinking quality standards. A fact sheet on perchlorate can be found on the EPA web site at <http://www.epa.gov/safewater/perchlorate/perchlorate.html>

Thank you for allowing us to continue providing your family with clean, quality water this year. The employees of the City of Aberdeen work around the clock to provide top quality water to the entire community. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please call our office if you have questions.

City of Aberdeen Wellhead Protection Program

What is Wellhead Protection?

Wellhead protection is a strategy designed to protect public drinking water supplies by managing the land surface around a well where activities might affect the quality of the water.

What is the City doing?

There are three components to a wellhead protection program.

1. Wellhead Protection Plan.
2. Wellhead Protection Ordinance.
3. Education.

The City has undertaken the development of a Wellhead Protection Plan for a variety of reasons, including the lack of attractive alternatives to the well field and the vulnerability of the relatively shallow supply wells to potential contamination.

The goal of the Wellhead Protection Plan is to maintain viable water supplies by protecting the raw water source-in this case the aquifer supplying the City's groundwater wells. The purpose of the plan is to:

- Delineate the area contributing water to the source.
- Provide an overview of the susceptibility of the source to contaminants.
- Identify actual and potential sources of contamination within the contributing area.
- Provide a management plan to address activities and properties that threaten the source.
- Provide monitoring practices that will provide early warning of impending problems.
- Provide a contingency plan to address threats and maintain the water supply quality.
- Educate the public on the need to protect the source.

The Wellhead Protection Program ordinance was adopted through legislation by the City Council on August 9, 2004. The City of Aberdeen conducted a public educational program meeting about the Wellhead Protection Program on September 15, 2004.

You can learn more about the Wellhead Protection Plan and Ordinance by visiting the City's website at www.aberdeen-md.org.